

# Certificate



Certificate no.

US 72082508 03

**License Holder:**

Bernecker & Rainer-Industrie  
Elektronik GmbH  
B&R Strasse 1

5142 Eggelsberg  
Austria

**Manufacturing Plant:**

Bernecker & Rainer-Industrie  
Elektronik GmbH  
B&R Strasse 1

5142 Eggelsberg  
Austria

Test report no.: USA-MHA 30881965 002

Client Reference: Franz Kaufleitner

Tested to: IEC 61508-2:2000  
IEC 61508-3:1998  
IEC 61508-4:1998  
see also previous page[s]

**Certified Product:** Safety Related Programmable Electronic System License Fee - Units

**Addition:**

**Model Designation:**

SafeLOGIC: 1) X20SL8010, X20SL8011  
X20 SafeIO: 2) X20SO2110, 3) X20SC2432, 4) X20SO4110  
Remote Module: 5) X67SC4122.L12

Rated Voltage: 1) DC 24V  
Output Ratings: 2) DC 24V/0.5A (1A max. per module)  
3) AC 48V/6A or DC 24V/6A (relays contacts)  
4) DC 24V/0.5A (2A max. per module)  
5) DC 24V/2A (5A max. per module)

Appendix: 1, 1-2


Licensed Test mark:



Signature

Date of Issue  
(day/mo/yr)

10/02/2011

  
Dipl.-Ing. M. Glagla  
QA Certification Officer