



Translation

In any case, the german original shall prevail.

Fachausschuss „Elektrotechnik“ • Postfach 510580 • 50941 Köln

Bernecker + Rainer
Industrie-Elektronik GmbH
B & R Straße 1
5142 Eggelsberg 120
Austria

Ihr Zeichen
Ihre Nachricht vom
Unser Zeichen LB.550.03/09-246 bat-wg
(bitte stets angeben)
Ansprechpartner/in
Telefon Herr Batzke
0351-457-3322
Fax 0351-3148-3309
E-Mail batzke.heinz@bgete.de
Datum 13.11.2009

Certificate of inspection 09001

Product: Modular control system X67

Intended use: Safety passing of the output signal of an external safety switchgear without automatic start:

Inspection procedure: ISO 13849-2:2003 Annex D.5
“Safety of machinery - Safety-related parts of control systems - Part 2: Validation”

Remarks: The affect principle was judged “Grind in a safety switchgear into operating voltage supply in the modular control system X67”.
Safety switching of the system outputs is ensured only by an external safety switchgear without automatics starts.

The safety deactivation signal of an external safety switchgear will be through the control system not affect uncertainly.

The validity of the inspection certificate shall cease no later than:

31.12.2014

- Mehlem -
Head of inspection body

09001-IB-Bernecker + Rainer-E.doc