



EG-Baumusterbescheinigung

Nr. M6A 041745 0013 Rev. 01

Zertifikatsinhaber:

B&R
Industrial Automation GmbH
B&R Strasse 1
5142 Eggelsberg
ÖSTERREICH

Produkt:

**Sicherheitsgerichtete programmierbare
elektronische Systeme**

Modell(e):

B&R-Safety-System: mappSafety

Kenndaten:

Sicherheitskennzahlen:

bis zu SIL 3	IEC 61508-1:2010
	IEC 61508-2:2010
	IEC 61508-3:2010
	IEC 61511-1:2016/A1:2017
	IEC 62061:2021
	EN 61800-5-2:2017
bis zu Kat 4, PL e	ISO 13849-1:2023

Diese EG-Baumusterbescheinigung bestätigt die Übereinstimmung des bezeichneten Anhang IV-Produktes mit den einschlägigen Bestimmungen gemäß Artikel 12(3) b bzw. 12(4) a der Richtlinie des Rates 2006/42/EG für Maschinen. Prüfgrundlage ist ausschließlich das zur Prüfung vorgestellte Prüfmuster sowie dessen technische Dokumentation. Details siehe bitte: www.tuvsud.com/ps-zert

Prüfbericht Nr.:

BE94015C

Gültig bis: 2029-02-27

Datum, 2024-02-29

(Matthias Ramold)

Seite 1 von 1

TÜV SÜD Product Service GmbH ist benannte Stelle gemäß der Richtlinie des Rates Nr. 2006/42/EG für Maschinen, notifiziert durch Veröffentlichung im Amtsblatt der EG mit der Kennnummer 0123.

TÜV SÜD Product Service GmbH • Zertifizierstelle • Ridlerstraße 65 • 80339 München • Deutschland



Product Service

EC-Type Examination Certificate

No. M6A 041745 0010 Rev. 03

Holder of Certificate: **B&R**
Industrial Automation GmbH
B&R Strasse 1
5142 Eggelsberg
AUSTRIA

Product: **Automation Equipment, Safety Related**

Model(s): **B&R-Safety-System: SafeLOGIC, SafeIO**

Parameters:

Supply voltage:	24 V
up to SIL 3	IEC 61508-1:2010
	IEC 61508-2:2010
	IEC 61508-3:2010
	IEC 61511-1:2016/A1:2017
	IEC 62061:2021
up to Cat 4, PL e	ISO 13849-1:2023

This EC Type Examination Certificate is issued according to Article 12(3) b or 12(4) a of Council Directive 2006/42/EC relating to machinery. It confirms that the listed Annex-IV equipment complies with the principal protection requirements of the directive. It refers only to the sample submitted to TÜV SÜD Product Service GmbH for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: **BE85343T**

Valid until: 2029-02-27

Date, 2024-02-29

(Matthias Ramold)

Page 1 of 1

TÜV SÜD Product Service GmbH is Notified Body according to Council Directive 2006/42/EC relating to machinery, notified by publication in the Official Journal of the EC with identification No.0123.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany



List for tracking of the version releases of components of the safety related automation system:
Liste zur Verfolgung der Versionsfreigaben der Komponenten des sicheren Automatisierungssystems:

B&R Safety System: SafeLOGIC, SafeIO

EC-Type Examination Certificate No. M6A 041745 0010

Rail

Manufacturer / Hersteller

Testing body / Prüfstelle

B&R
Industrial Automation GmbH
B&R Strasse 1
5142 Eggelsberg, Austria

TÜV SÜD Rail GmbH
Barthstrasse 16
80339 München, Germany

B&R Safety System: SafeLOGIC, SafeIO

EC-Type Examination Certificate No. M6A 041745 0010

List of certified SafeLOGIC versions:

Liste der zertifizierten SafeLOGIC Versionen:

No. Nr.	Product name Produktbezeichnung	Certified versions Zertifizierte Versionen		
		Hardware Revision	Firmware Version	Datasheet Version ⁽¹⁾
SL.1	X20SL8000 SafeLOGIC Standard	A3, A5, B0 C0, D0, E0, F0, G0, H0	263, 275, 284 296, 297, 299	1.51
SL.2	X20SL8001 SafeLOGIC Plus			
SL.3	X20SL8010 SafeLOGIC Standard, SafeMOTION	B0 C0, D0, E0, F0, G0, H0	274, 284, 296 297, 299	1.51
SL.4	X20SL8011 SafeLOGIC Plus, SafeMOTION			
SL.5	X20SLH000 SafeLOGIC Standard, SERCOS III Interface	B0, C0, D0, E0, F0, G0, G3, G6, G9	275 298	1.30
SL.6	X20SLH001 SafeLOGIC Plus, SERCOS III Interface			
SL.7	X20SLX210 SafeLOGIC with Safe Digital Input, 2 channel	B0, B2, C0, D0, D3, D5, E0	300, 302, 311, 313, 320, 324, 326, 330, 338, 340	1.141
SL.8	X20SLX410 SafeLOGIC with Safe Digital Input, 4 channel			
SL.9	X20SLX910 SafeLOGIC with Safe Digital Input, 20 channel	B0, B2, C0, D0, D3, D5, D7, E0, F0, G0	300, 302, 311, 312, 313, 320, 324, 326, 330, 338, 340	
SL.10	X20SL8100 SafeLOGIC Basic	B0, B2, B4, B5, B6, C0, C3, C5, C7, C9, D0, E0, F0, F3, G0	301, 303, 304, 306, 308, 310, 311, 312, 320, 322, 324, 325, 326, 327, 329, 331, 336, 337, 338, 340, 341, 342	1.142
SL.11	X20SL8101 SafeLOGIC Basic with local X2X	B0, B3, C0, C3, C5, C7, D0, E0, E3, F0, G0, H0	308, 310, 311, 312, 320, 322, 324, 325, 326, 327, 329, 331, 336, 337, 338, 340, 341, 342	1.142
SL.12	X20SL8110 SafeLOGIC Basic with IF – Slot	B3, B5, B7, C0, D0, D3, E0, F0	320, 322, 324, 325, 326, 327, 329, 331, 336, 337, 338, 340, 341, 342	1.142
SL.13	X20SLX811 SafeLOGIC with Safe Digital Input, 8 channel	B3, B5, C0, C3, D0, D3, E0, F0	320, 321, 322, 324, 326, 330, 335, 338, 340	1.141

⁽¹⁾ the certificate scopes all not stated but released minor versions / das Zertifikat beinhaltet alle nicht angegebenen freigegebenen Unterversionen

⁽²⁾ not relevant / nicht relevant

⁽³⁾ xx-yy= reference to column "Hardware Revision" / Referenz zur Spalte "Hardware Revision"

It is not accepted to reproduce any part of this list without prior written authorization of TÜV SÜD Rail GmbH
Diese Liste darf ohne die schriftliche Genehmigung der TÜV SÜD Rail GmbH nicht auszugsweise vervielfältigt werden



List for tracking of the version releases of components of the safety related automation system:
Liste zur Verfolgung der Versionsfreigaben der Komponenten des sicheren Automatisierungssystems:

B&R Safety System: SafeLOGIC, SafeIO

EC-Type Examination Certificate No. M6A 041745 0010

Rail

SL.14	X20SLX806 SafeLOGIC with 8 channel SI, 6 channel SO	B3, B5, C0, C3, D0, E0, E3, F0, G0, H0	321, 322, 324, 326, 330, 335, 338, 340	1.141
SL.15	X20SLX842 SafeLOGIC with 8 channel SI, 6 channel SO	B3, B5, C0, C3, D0, E0, E3, F0, G0, H0		
SL.16	X20SLX402 SafeLOGIC with 4 channel SI, 2 channel SO	B1, B3, C0, C3, D0, E0, E3, F0, G0		
SL.17	X20SLH000-1 SafeLOGIC Basic, SERCOS III Interface	C0, D0	337, 341, 342	1.142
SL.18	X20SLH001-1 SafeLOGIC Basic, SERCOS III Interface			

Tool.1	SCMar openSAFETY Configuration Manager for X20SLX devices	--- (2)	300, 310, 312, 313, 321, 324, 325, 326, 327, 328	--- (2)
Tool.2	AsSafety Library Control & Configuration Services for SafeLOGIC devices	--- (2)	300, 301, 302, 320, 321, 323, 324	--- (2)
Tool.3	SafeTableCheck Library Check & Configuration Services for Table handling	--- (2)	320	--- (2)
Tool.4	MpSafetyX mapp Technology for extended safety functions	--- (2)	320	--- (2)
Tool.5	SRC Help Tool Configuration Tool for SafeDesigner Robotic Libraries	--- (2)	3.61.0 3.70.0	--- (2)
cSL.2	X20cSLX410 SafeLOGIC with Safe Digital Input, 4 channel	C0, D0, D3, D5, E0	300, 302, 311, 313, 320, 324, 326, 330, 338, 340	1.141
cSL.3	X20cSLX910 SafeLOGIC with Safe Digital Input, 20 channel	D3, D5, D7, E0, F0, G0	300, 302, 311, 312, 313, 320, 324, 326, 330, 338, 340	
cSL.4	X20cSL8100 SafeLOGIC Basic	B0, B7 C3, C5, C7, C9, D0, E0, F0, F3, G0	301, 303, 304, 306, 308, 310, 311, 312, 320, 322, 324, 325, 326, 327, 329, 331, 336, 337, 338, 340, 341, 342	1.142
cSL.5	X20cSL8101 SafeLOGIC Basic with local X2X	C0, C3, C5, C7, D0, D3, E0, E3, F0, G0, H0	308, 310, 311, 312, 320, 322, 324, 325, 326, 327, 329, 331, 336, 337, 338, 340, 341, 342	1.142
cSL.11	X20cSLX402 SafeLOGIC with 4 channel SI, 2 channel SO	D0, E0, E3, F0, G0	324, 326, 330, 335, 338, 340	1.141

**List of certified SafeDESIGNER versions:
Liste der zertifizierten SafeDESIGNER Versionen:**

No. Nr.	Product name Produktbezeichnung	Certified versions Zertifizierte Versionen ⁽¹⁾
SD.1	SafeDESIGNER SafeDESIGNER Engineering Version	2.58, 2.59, 2.70, 2.71, 2.80, 2.81, 2.82, 2.83, 2.90, 2.91, 3.0.16, 3.0.17, 3.0.18, 3.1.0, 3.3.0, 3.4.0, 3.4.1, 3.4.2, 4.1.0, 4.1.1, 4.1.2, 4.1.3, 4.2.0, 4.2.1, 4.2.2, 4.2.3, 4.2.4, 4.2.5, 4.2.6, 4.3.0, 4.3.1, 4.3.2, 4.3.3, 4.3.4, 4.3.5, 4.4.0, 4.4.1
SD.2	SafeDESIGNER SafeDESIGNER Maintenance Version	

⁽¹⁾ the certificate scopes all not stated but released minor versions / das Zertifikat beinhaltet alle nicht angegebenen freigegebenen Unterversionen

⁽²⁾ not relevant / nicht relevant

⁽³⁾ xx-yy= reference to column "Hardware Revision" / Referenz zur Spalte "Hardware Revision"

It is not accepted to reproduce any part of this list without prior written authorization of TÜV SÜD Rail GmbH
Diese Liste darf ohne die schriftliche Genehmigung der TÜV SÜD Rail GmbH nicht auszugsweise vervielfältigt werden



List for tracking of the version releases of components of the safety related automation system:
Liste zur Verfolgung der Versionsfreigaben der Komponenten des sicheren Automatisierungssystems:

B&R Safety System: SafeLOGIC, SafeIO

EC-Type Examination Certificate No. M6A 041745 0010

Rail

List of certified SafeDESIGNER Libraries:

Liste der zertifizierten SafeDESIGNER Bibliotheken:

No. Nr.	Product name Produktbezeichnung	Certified versions Zertifizierte Versionen	
		Library Name	Library Version
LIB.1	SafeDESIGNER PLCopen Library	PLCopen_SF	Version 1.00 from 09/14/07 09:09:21 Version 1.1 from 04/05/17 11:34:16
LIB.2	SafeDESIGNER Motion Library	PLCopen_Motion_SF	Version 1.1 from 12/07/09 14:09:58
LIB.3	SafeDESIGNER Motion Library, Extension for positioning functions	PLCopen_Motion_SF_2	Version 2.0 from 02/16/11 11:28:33 Version 2.1 from 02/09/12 10:31:01 Version 2.2 from 10/22/12 14:20:54 Version 3.0 from 07/05/13 08:11:42 Version 4.0 from 01/27/14 11:45:47
LIB.4	SafeDESIGNER Table Library	Table_SF	Version 1.1 from 12/14/11 13:20:22 Version 1.2 from 11/08/12 17:54:56 Version 1.3 from 07/04/13 15:25:25 Version 1.4 from 07/26/17 12:44:34
LIB.5	SafeDESIGNER Robotic Library	RoboticCtrl_SF	Version 1.0 from 02/15/12 09:30:15 Version 1.13 from 11/08/12 17:38:46 Version 1.22 from 10/03/13 14:22:56
		RoboticCtrl_SF_2	Version 0.70 from 12/16/14 12:53:40 Version 0.71 from 12/03/15 10:04:48
		RoboticCtrl_SF_3	Version 1.0 from 04/11/16 15:49:47 Version 2.0 from 09/19/16 13:17:10
		RoboticCtrl_SF_4	Version 1.0 from 04/12/18 15:53:40
LIB.6	SafeDESIGNER Utilities Library	Utilities_SF	Version 1.0 from 07/26/13 11:16:27 Version 1.1 from 03/18/15 14:25:30 Version 1.2 from 09/30/16 07:48:59 Version 1.3 from 05/31/17 09:49:14
LIB.7	openSAFETY Motion Profile Support 3 rd party drive accessibility	openSAFETY_Motion_SF	Version 1.0 from 07/06/16 09:28:15
LIB.8	openSAFETY Motion Profile Support B&R drives extensions	openSAFETY_BuR_Motion_SF	Version 1.0 from 08/29/16 16:14:40
LIB.9	SafeDESIGNER PROFIsafe Library	ProfiSafe_SF	Version 1.0 from 05/06/15 09:42:23 Version 1.1 from 06/19/17 13:31:48 Version 1.2 from 09/15/17 08:17:30
LIB.10	SafeDESIGNER SafeOPTION Library	SafeOPTION_SF	Version 1.0 from 12/14/16 08:31:57
LIB.11	SafeDESIGNER Mathematics Library	Math_Uutilities_SF	Version 1.0 from 03/01/17 10:28:11
LIB.12	SafeDESIGNER User1 Utilities Library	User1_Uutilities_SF	Version 1.0 from 08/08/17 13:01:22
LIB.13	SafeDESIGNER Lightcurtain Library	LightCurtain_SF	Version 1.2 from= 11/10/17 12:44:34 Version 1.3 from= 01/26/18 14:32:16
LIB.14	SafeDESIGNER DATAtoSafeDATA Transformation Library	DATA_to_SafeDATA_SF	Version 1.0 from 01/11/18 13:44:58
LIB.15	SafeDESIGNER Press Library	PLCopen_Press_SF	Version 1.0 from 10/10/14 08:34:06

⁽¹⁾ the certificate scopes all not stated but released minor versions / das Zertifikat beinhaltet alle nicht angegebenen freigegebenen Unterversionen

⁽²⁾ not relevant / nicht relevant

⁽³⁾ xx-yy= reference to column "Hardware Revision" / Referenz zur Spalte "Hardware Revision"

It is not accepted to reproduce any part of this list without prior written authorization of TÜV SÜD Rail GmbH
Diese Liste darf ohne die schriftliche Genehmigung der TÜV SÜD Rail GmbH nicht auszugsweise vervielfältigt werden



List for tracking of the version releases of components of the safety related automation system:
Liste zur Verfolgung der Versionsfreigaben der Komponenten des sicheren Automatisierungssystems:

B&R Safety System: SafeLOGIC, SafeIO

EC-Type Examination Certificate No. M6A 041745 0010

Rail

List of certified SafeIO versions:

Liste der zertifizierten SafeIO Versionen:

No. Nr.	Product name Produktbezeichnung	Certified versions Zertifizierte Versionen		
		Hardware Revision	Firmware Version	Datasheet Version ⁽¹⁾
SA.1	X20SA4430 Safe Analog Input, 2x2 channel	B0, C0, D0, D3, E0, E3, F0	295, 301, 302, 311, 321, 322, 330, 331, 333, 334	1.141
SA.2	X20ST4492 Safe Temperature Input, 2x2 channel	B0, B2, B3, B5 C0, C3, D0	295, 301, 302, 311, 321, 322, 330, 331, 333, 334	1.141
SI.1	X20SI2100 Safe Digital Input, 2 channel	A9, B0, C0, D0, D3, E0, E5, F0, G0, H0, I0, J0, J3, J5, J7, K0, L0	259, 260, 262, 272, 273, 275, 281, 290, 300, 301, 305, 320, 325, 330, 331, 332, 333, 340	1.141
SI.2	X20SI4100 Safe Digital Input, 4 channel			
SI.3	X20SI9100 Safe Digital Input, 20 channel			
SI.4	9AX2X.01-000 Safe Digital Input, 8 channel SI	B0, B3, B5, B9, BA, C0	320, 322, 325, 330, 570	1.140
SI.5	9APLK.01-000 Safe Digital Input, 8 channel SI	B0, B3, B5, B9, BA, C0		
SI.6	X20SI8110 Safe Digital Mixed with 8 channel SI	B0, B3, B5, B7, C0, D0, E0, E3, F0, G0	320, 322, 325, 330, 332, 333, 340	1.141
SI.7	B050006543xx-yy ⁽³⁾ Safe Digital Input, 8 channel SI	00-03, 00-04, 00-05, 00-07, 00-08	320, 322, 325, 330, 570	1.140
SI.8	B050006677xx-yy ⁽³⁾ Safe Digital Input, 8 channel SI	00-03, 00-04, 00-05, 00-07, 00-08		
SI.9	X20SI4110 Safe Digital Mixed with 4 channel SI	B0, C0, D0, E0	333, 340	2.20
SO.1	X20SO2110 Safe Digital Output, 2 channel, 0.5 A	A9, B0, C0, C3, C6, D0, D3, E0, E5, F0, G0, H0, I0, I3, J0, J3, K0, L0, M0	260, 261, 262, 274, 275, 280, 281, 300, 320, 325, 330, 331, 332, 333	1.141
SO.2	X20SO2120 Safe Digital Output, 2 channel, 2 A			
SO.3	X20SO4110 Safe Digital Output, 4 channel, 0.5 A			
SO.4	X20SO4120 Safe Digital Output, 4 channel, 2 A			
SO.5	X20SO6300 Safe Digital Output, 6 channel, 0.2 A	B2, C0, D0, D3, D5, E0, F0	295, 300, 320, 325, 330, 331, 332, 333	1.141
SO.6	X20SO2530 Safe Digital Output, 2 channel relay SO, 240 V	B0, C0, D0, E0, E3, E6, E9, F0, G0, H0, I0	291, 300, 320, 325, 330, 331, 332, 333	1.141
SO.7	X20SP1130 Safe Digital Output, 1 channel, 10 A, Power Supply	B2, B3, B4, B7, B9, C0, D0	293, 300, 320, 325, 330, 331, 332, 333	1.141
SO.8	X20SO6530 Safe Digital Output, 6 channel relay SO, 240 V	B0, B3, B5, C0	540, 541	1.141
SC.1	X20SC2432 Safe Digital Mixed, 2 channel SI, 2 channel relay 6 A	B0, B1, C0, C5, D0, E0, F0, G0, G3, G5, G7, H0, I0, J0	271, 272, 273, 281, 290, 300, 301, 305, 320, 325, 330, 331, 332, 333, 340	1.141
SC.2	X20SC2212 Safe Digital Mixed, 6 channel SI, 2 channel SO, 0.5 A	B1, B4, C0, C3, C5, C7, D0, E0	290, 300, 301, 305, 320, 326, 330, 331, 332, 333, 340	1.141

⁽¹⁾ the certificate scopes all not stated but released minor versions / das Zertifikat beinhaltet alle nicht angegebenen freigegebenen Unterversionen

⁽²⁾ not relevant / nicht relevant

⁽³⁾ xx-yy= reference to column "Hardware Revision" / Referenz zur Spalte "Hardware Revision"

It is not accepted to reproduce any part of this list without prior written authorization of TÜV SÜD Rail GmbH
Diese Liste darf ohne die schriftliche Genehmigung der TÜV SÜD Rail GmbH nicht auszugsweise vervielfältigt werden



List for tracking of the version releases of components of the safety related automation system:
Liste zur Verfolgung der Versionsfreigaben der Komponenten des sicheren Automatisierungssystems:

B&R Safety System: SafeLOGIC, SafeIO

EC-Type Examination Certificate No. M6A 041745 0010

Rail

SC.3	X20SC0806 Safe Digital Mixed with 8 channel SI, 6 channel SO	B0, B3, B5, B7, C0, D0, E0, E3, F0, G0, H0, I0	320, 322, 325, 330, 332, 333, 340	1.141
SC.4	X20SC0842 Safe Digital Mixed with 8 channel SI, 6 channel SO	B0, B3, B5, C0, D0, E0, E3, F0, G0, H0, I0		
SC.5	X20SC0402 Safe Digital Mixed with 4 channel SI, 2 channel SO	B0, B3, B5, B7, C0, D0, E0, E3, F0, G0, H0		
SD.1	X20SD1207 safe digital counter module, 1 failsafe counter channel, 7 kHz, 24 VDC	B6, B7, B8, B9 C0, C3, C5, D0, D3	297, 300, 301, 310, 320, 326, 330, 331, 332, 333, 334, 335	1.143
SRT.1	X20SRT806 ReAction for Safety with 8 channel SI, 6 channel SO	B5, B7, C0, D0, E0, F0	320, 327, 330, 331, 332, 333	1.141
SRT.2	X20SRT842 ReAction for Safety with 8 channel SI, 6 channel SO	B5, B7, C0, D0, E0, F0, G0		
SRT.3	X20SRT402 ReAction for Safety with 4 channel SI, 2 channel SO	B3, B5, C0, D0, E0, F0		
X67.1	X67SC4122.L12 Safe Digital Mixed, 8 channel SI, 4 channel SO 2 A	A6, B0, B2, C0, D0, E0, E3, E5, F0, F3, G0, H0, I0, J0	272, 280, 290, 300, 301, 305, 320, 322, 325, 330, 332, 333, 340	1.141
X67.2	X67SI8103 Safe Digital Input, 8 channel SI	B0, B2, C0, D0, D3, D5, D7, E0, F0, G0, H0	290, 300, 301, 305, 320, 325, 326, 330, 331, 332, 333, 340	1.141
cSA.1	X20cSA4430 Safe Analog Input, 2x2 channel	C0, D0, D3, E0, E3, F0, F3	295, 301, 302, 311, 321, 322, 330, 331, 333, 334	1.141
cSA.2	X20cST4492 Safe Temperature Input, 2x2 channel	C0, C3, D0	295, 301, 302, 311, 321, 322, 330, 333, 334	1.141
cSI.2	X20cSI4100 Safe Digital Input, 4 channel	I0, J0, J3, J5, J7, K0, L0	259, 260, 262, 272, 273, 275, 281, 290, 300, 301, 305, 320, 325, 330, 331, 332, 333, 340	1.141
cSI.3	X20cSI9100 Safe Digital Input, 20 channel	F0, F3, F5, F7, G0, H0, I0	272, 290, 300, 301, 305, 320, 325, 330, 331, 332, 333, 340	1.141
cSO.3	X20cSO4110 Safe Digital Output, 4 channel, 0.5 A	I0, I3, J0, J3, K0, L0, M0	260, 261, 262, 274, 275, 280, 300, 320, 325, 330, 331, 332, 333	1.141
cSO.4	X20cSO4120 Safe Digital Output, 4 channel, 2 A			
cSO.5	X20cSO6300 Safe Digital Output, 6 channel, 0.2 A	D0, D3, D5, E0, F0	295, 300, 320, 325, 330, 331, 332, 333	1.141
cSO.6	X20cSO2530 Safe Digital Output, 2 channel relay SO, 240 V	B3, B5, F0, G0, H0, I0	320, 325, 330, 331, 332, 333	1.141
cSO.8	X20cSO6530 Safe Digital Output, 6 channel relay SO, 240 V	B0, C0	540, 541	2.18
cSC.1	X20cSC2432 Safe Digital Mixed, 2 channel SI, 2 channel relay 6 A	G0, G3, G5, G7, H0, I0, J0	271, 272, 273, 281, 290, 300, 301, 305, 320, 325, 330, 331, 332, 333, 340	1.141
cSC.2	X20cSC2212 Safe Digital Mixed, 6 channel SI, 2 channel SO, 0.5 A	B3, B5, C0, C3, C5, C7, D0, E0	290, 300, 301, 305, 320, 326, 330, 331, 332, 333, 340	1.141
cSD.1	X20cSD1207 safe digital counter module, 1 failsafe counter channel, 7 kHz, 24 VDC	C0, C3, C5, D0, D3	297, 300, 301, 310, 320, 325, 330, 331, 332, 333, 334, 335	1.143

⁽¹⁾ the certificate scopes all not stated but released minor versions / das Zertifikat beinhaltet alle nicht angegebenen freigegebenen Unterversionen

⁽²⁾ not relevant / nicht relevant

⁽³⁾ xx-yy= reference to column "Hardware Revision" / Referenz zur Spalte "Hardware Revision"

It is not accepted to reproduce any part of this list without prior written authorization of TÜV SÜD Rail GmbH
Diese Liste darf ohne die schriftliche Genehmigung der TÜV SÜD Rail GmbH nicht auszugsweise vervielfältigt werden



List for tracking of the version releases of components of the safety related automation system:
Liste zur Verfolgung der Versionsfreigaben der Komponenten des sicheren Automatisierungssystems:

B&R Safety System: SafeLOGIC, SafeIO EC-Type Examination Certificate No. M6A 041745 0010

Rail

	Release by Test Body: Freigabe Prüfstelle:	Release by Certification Body: Freigabe Zertifizierstelle:	Release by Manufacturer: Freigabe Hersteller:
Date: Datum:	Klaus		Stefan
Signature: Unterschrift:	Leupold		Schoenegger
	Digital unterschieden von Klaus Leupold Datum: 2024.02.28 08:18:07 +01'00'	Digital unterschieden von Matthias Ramold Datum: 2024.02.29 13:04:49 +01'00'	Digital unterschrieben von Stefan Schoenegger Datum: 2024.03.06 06:54:17 +01'00'

Dietmar
Bruckner

Digital signiert von
Dietmar Bruckner
Datum: 2024.03.06
07:45:47+01'00'